### **MS D270**





#### **Key Parameters**

 $V_{RRM}$ = 1600V= 270A I<sub>F(AV)</sub> = 4900A IFSM  $V_{F(TO)}$ = 0.76 V $= 0.56 \text{m}\Omega$ ГF

#### **Features**

- Full blocking capability over wide temperature range
- Hermetic metal case with glass insulator
- Flat round base

## Applications Power Supplies

- Uncontrolled Rectifiers
- Battery Chargers

### **Ordering Information**

MS D	270	N	хх	F	В
Rectifier Diode	Current code	Polarity R= Base Anode N= Base Cathode	Voltage Code Code X 100 = V <sub>RRM</sub>	F = Flat Base	Technology B = Solder Bond Technology
Order Code MS D270N16FB: 1600V VRRM, Flat Base, Diode with base Cathode					

Date of Publication: 25.03.2015 Prepared by : ABA Approved by: RBS Revision : 0

## **MS D270**




Symbol	Characteristic	Conditions	Tj [°C]	Value	Unit
BLOCKI	NG				
V RRM	Repetitive peak reverse voltage		180	200 - 1600	V
V RSM	Non-repetitive peak reverse voltage		180	300 - 1700	V
I RRM	Repetitive peak reverse current	V= V rrm	180	30	mA
CONDUC	CTING				
l F (AV)	Mean forward current	180° sin ,50 Hz, T <sub>c</sub> =125°C 180° sin ,50 Hz, T <sub>c</sub> =130°C		270 250	А
I FRMS	RMS current	T <sub>c</sub> =125°C		424	Α
1	Surge forward current	Sine wave, 10 ms Without reverse voltage	25	4900	Α
I FSM			180	4500	А
		Sine wave, 10 ms	25	120 x 10 <sup>3</sup>	A <sup>2</sup> s
l² t	l² t	Without reverse voltage	180	101 x 10 <sup>3</sup>	A <sup>2</sup> s
VF	Forward voltage	On-state current = 785A	180	1.28	V
V F(TO)	Threshold voltage		180	0.76	V
r <sub>F</sub>	Forward slope resistance		180	0.56	mΩ
MOUNTI	NG				
R th(j-c)	Thermal impedance, sin 180°	Junction to case		0.18	°C/W
R th(c-h)	Thermal impedance	Case to heatsink		0.05	°C/W
Тj	Max. junction temperature			180	°C
T stg	Storage temperature			-40 180	°C
М	Mounting torque			18	NM
W	Weight (Approx.)			250	gm

Prepared by : ABA	Date of Publication : 25.03.2015	
Approved by : RBS	Revision : 0	


## **MS D270**







## **MS D270**







#### TRANSIENT THERMAL IMPEDANCE




Prepared by : ABA	Date of Publication : 25.03.2015	
Approved by : RBS	Revision : 0	

## **MS D270**



#### **Outline**



#### **MS Power GmbH**

Mergenthalerallee 79-81 65760 Eschborn, Germany Web: www.mspowergroup.com Mail: info@mspowergroup.de

#### Sales & Enquiry:

sales@mspowergroup.de

**Technical Support:** 

solution@mspowergroup.de

**After sales Service:** 

service@mspowergroup.de

Phone: +49 (0) 6196/7768 666 Fax: +49 (0) 6196/7757 888



Prepared by : ABA	Date of Publication : 25.03.2015	
Approved by : RBS	Revision	:0

### **MS D270**



#### Terms & Conditions of usage:

The data contained in this product datasheet is exclusively Intended for technically trained staff. You and your technical departments will have to evaluate the suitability of the product for the intended application and the completeness of the product data with respect to such application. This product datasheet is describing the characteristics of this product for which a warranty is granted. Any such warranty is granted exclusively pursuant the terms and conditions of the supply agreement. There will be no guarantee of any kind for the product and its characteristics. The information in the valid application-and assembly notes of the device must be considered.

Should you require product information in excess of the data given in this product datasheet or which concerns the specific application of our product, please contact the sales office, which is responsible for you (see <a href="https://www.mspowergroup.com">www.mspowergroup.com</a>). For those that are specifically interested we may provide application notes.

Due to technical requirements our product may contain dangerous substances. For information on the types in question please contact the sales office, which is responsible for you.

Should you intend to use the Product in aviation applications, in health or live endangering or life support applications, please notify. Please note, that for any such applications we urgently recommend

- -to perform joint Risk and Quality Assessments;
- -the conclusion of Quality Agreements;
- -to establish joint measures of an ongoing product survey, and that we may make delivery depended on the realization of any such measures.

If and to the extent necessary, please forward equivalent notices to your customers.

Changes of this product datasheet are reserved.

Prepared by : ABA	Date of Publication : 25.03.2015		
Approved by : RBS	Revision : 0		